

**ADDENDUM 001
REQUEST FOR BIDS
RFQ NUMBER: D9111651R9**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original quote. If original quote has been submitted sign and fax back to 417-469-3449. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Carmella Green Int. GS Specialist
Contractor/Offeror Signature	Department of Transportation <i>Carmella Green</i>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 4/14/11

ADD:

1. Contractor to provide the 2" galvanized pipe and 2" locking ball valve for draining the pit area. Product submittals on these items to be approved by Modot personnel prior to installation and placement of this valve and pipe is coordinated with contractor and MoDot personnel to ensure proper drainage when needed.

2. The 1' box that is formed around the water lines will need filled back in with gravel and 3" of concrete put back in that area, so that it can be easily removed if needed to service water hydrant. The joint between the boxed area and concrete floor area will need blown free of debris and filled with sealant.